

**6. Equipment Use.**

The line terminals on a current transformer cabinet will be used for service entrance conductors only. A tap box is preferred for grouped meter connections except to feed separately metered space conditioning or water heating as shown in Section 7. In unusual cases, the Detroit Edison Planner may grant an exception.

**7. Equipment Relocation.**

If the metering point is relocated, the existing current transformer cabinet can be left in place and used as a junction box providing the following procedure is followed:

- (a) The customer's contractor must furnish and install the required jumper bars.
- (b) The customer's contractor is responsible for keeping the customer in service during the cutover of circuits.
- (c) The customer's contractor must furnish and install the new current transformer cabinet subject to Detroit Edison specifications and approval.

**8. Acceptable Current Transformer Cabinets and Transockets.**

8.1 The following current transformer cabinets have been accepted for use in the Detroit Edison Service Area. Manufacturers desiring to have their equipment listed may contact Detroit Edison Meter Engineering 313 389-7711.

- (c) *Continental Electrical Products* by Cotson Fabricating, 1005 Troy Ct, Troy, MI 48083, 248.589.2758, <http://www.Cont-USA.com/>